

GOVERNMENT OF ARUNACHAL PRADESH
OFFICE OF THE ASSISTANT ENGINEER
PUBLIC HEALTH ENGINEERING AND WATER SUPPLY SUB DIVISION YOMCHA

Water Test Report

No. AEY/PHEDA/Lab/2025-26/93

Dated: 08/10/2026

- 1 Name/Source Govt Hr Sec School Yomcha
- 2 Sample collector Shri Boyi Gamlin
- 3 Date of sample collection 7/10/2026
- 4 Date of testing 7/10/2026
- 5 Method /Apparatus Photometer

Sl no	Parameters	Report	Range/Permissibel limit
1	Turbidity	0.2	0 - 100 NTU
2	Ph Value	7.6	6.5 - 8.5
3	Total Alkalinity	30	0 - 500 mg/l
4	Chloride	0.05	0 - 5 mg/l
5	Flouride	0.05	0 - 1.5 mg/l
6	Nitrate	0.06	0 - 1 mg/l
7	Total hardness	25	0 - 500 mg/l
8	Iron	0.01	0.1 mg/l
9	Chlorine	0.05	0.0 to 2.0 mg/l
10	Bacteriological test	Present/ Absent	Absent

Inference: The water sample tested is fit for human consumption.


Lab.assistant
PHE & WS Sub Division
Yomcha


Assistant Engineer
PHE & WS Sub Division
Yomcha